

Roy Romanow Provincial Laboratory **Environmental Services**

5 Research Drive Regina, Saskatchewan S4S 0A4

(306) 787-7138 / (306) 787-3140

Environmental Services Analysis Report - Final

Invoice Number:

3440873

Sample Location: Collected by:

Water Plant

Kelly Kish

SK05NE0001

Permit: 2277

Collected Date:

14-Aug-2023 5:50 AM

Received:

14-Aug-2023 1:30 PM

Reported:

15-Aug-2023 2:31 PM

KIPLING DIST.SYSTEM Water Source: Distributed

Submitted By:

Station #:

KIPLING TOWN OF

BOX 299 KIPLING, SK S0G 2S0

Invoice:

KIPLING TOWN OF

BOX 299 KIPLING, SK S0G 2S0

Toet

Analysis			iest		
	Result	Unit	Sask Guideline	Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

Submitter Phone Number:

306-736-2515

Emailed results to:

kiptown@sasktel.net

kellykish@swwa.ca

Comments:

Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water

2. See above for comment

Please include Invoice Number

Saskatchewan Health Authority

c/o Finance

with payment and remit to:

2180 23rd Avenue

Regina, Saskatchewan

S4S 0A5

Total Fees (including GST)

Tax Summary

G.S.T. (reg # 89583 0180 RT001)

1.10

23.00

0.00

\$23.00

Balance Due upon receipt of invoice.

Balance Owed

Amount Received: (No Payment Received)

Contact Us:

Result Interpretation:

Please contact your EPO for advice or phone 306-535-4347

Billing Inquiries:

Phone: 1-833-989-5353, Email: shaar@saskhealthauthority.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine:

.47

Total Chlorine:

.49

Turbidity:

.10

580-290-100