

## Environmental Services Analysis Report - Final

**Invoice Number:** 3511367  
**Sample Location:** 1911 Main St Town Shop  
**Collected by:** Kelly Kish **Permit:** 2277  
**Station #:** SK05NE0001 KIPLING DIST.SYSTEM

<b>Collected Date:</b>	11-Aug-2025	11:22 AM
<b>Received:</b>	12-Aug-2025	4:05 PM
<b>Reported:</b>	13-Aug-2025	2:15 PM
<b>Water Source:</b>	Distributed	

**Submitted By:** KIJLING TOWN OF  
BOX 299  
KIJLING, SK  
S0G 2S0

**Invoice:**  
KIPLING TOWN OF  
BOX 299  
KIPLING, SK  
S0G 2S0

<b>Analysis</b>	<b>Result</b>	<b>Unit</b>	<b>Sask Guideline</b>	<b>Test Comment</b>	<b>Fee</b>
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	<b>1</b>	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	<b>2</b>	

**Submitter Phone Number:** 306-736-8805

**Emailed results to:** b.ackerman@townofkipling.ca  
kellykish1964@gmail.com

**Comments:**

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include  
Invoice Number  
with payment  
and remit to:

**Saskatchewan Health Authority**  
c/o Accounts Receivable  
2180 23rd Avenue  
Regina, Saskatchewan  
S4S 0A5

Total Fees (including GST)	23.00
----------------------------	-------

Tax Summary 1.10  
G.S.T. (reg # 89583 0180 RT001)

Amount Received: (No Payment Received)	0.00
--	------

Balance Due upon receipt of invoice.

<b>Balance Owed</b>	<b>\$23.00</b>
---------------------	----------------

**Contact Us:**

**Result Interpretation:** Please contact your EPO for advice or phone 1-866-727-5420  
**Billing Inquiries:** Phone: 1-833-989-5353, Email: [SHAAR@saskhealthauthority.ca](mailto:SHAAR@saskhealthauthority.ca)

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine: .62                      Total Chlorine: .64                      Turbidity: .13