

Environmental Services Analysis Report - Final

Invoice Number: 3489053	Collected Date: 07-Oct-2024 11:59 AM
Sample Location: 604 Main St.	Received: 08-Oct-2024 2:57 PM
Collected by: Kelly Kish	Reported: 09-Oct-2024 2:19 PM
Station #: SK05NE0001	Water Source: Distributed
Permit: 2277	
KIPLING DIST.SYSTEM	

Submitted By:	Invoice:
KIPLING TOWN OF	KIPLING TOWN OF
BOX 299	BOX 299
KIPLING, SK	KIPLING, SK
S0G 2S0	S0G 2S0

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

Submitter Phone Number: 306-736-8805	Emailed results to: kiptown@sasktel.net kellykish1964@gmail.com
---	---

Comments:

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include Invoice Number with payment and remit to:

**Accounts Receivable Department
SHA - Financial Services
1920 College Avenue, 4th Floor W
Regina, Saskatchewan
S4P 0T1**

Total Fees (including GST)	23.00
----------------------------	-------

Tax Summary G.S.T. (reg # 89583 0180 RT001)	1.10
--	------

Amount Received: (No Payment Received)	0.00
--	------

Balance Due upon receipt of invoice.

Balance Owed	\$23.00
---------------------	----------------

Contact Us:

Result Interpretation: Please contact your EPO for advice or phone 306-535-4347
Billing Inquiries: Phone: (306) 766-5832, Email: corpFinance@rqhealth.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine: 0.84	Total Chlorine: 0.85	Turbidity: 0.13
---------------------	----------------------	-----------------