

Environmental Services Analysis Report - Final

Invoice Number: 3408386	Collected Date: 30-May-2022 7:50 AM	
Sample Location: 621 Main St	Received: 31-May-2022 3:46 PM	
Collected by: Kelly Kish	Reported: 01-Jun-2022 2:36 PM	
Station #: SK05NE0001	Water Source: Distributed	Permit: 2277 KIPLING DIST.SYSTEM

Submitted By: KIPLING TOWN OF BOX 299 KIPLING, SK S0G 2S0	Invoice: KIPLING TOWN OF BOX 299 KIPLING, SK S0G 2S0
--	---

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

Submitter Phone Number: 306-736-2515	Emailed results to: kiptown@sasktel.net kellykish@swwa.ca
---	---

Comments:

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include Invoice Number with payment and remit to:	Saskatchewan Health Authority c/o Finance 2180 23rd Avenue Regina, Saskatchewan S4S 0A5	Total Fees (including GST) Tax Summary G.S.T. (reg # 89583 0180 RT001)	23.00 1.10
		Amount Received: (No Payment Received)	0.00
Balance Due upon receipt of invoice.			
Balance Owed			\$23.00

Contact Us:

Result Interpretation: Please contact your EPO for advice or phone 306-535-4347

Billing Inquiries: Phone: (306) 766-5832, Fax: (306) 766-5188, Email: corpfinance@rqhealth.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine: .50	Total Chlorine: .52	Turbidity: .13
--------------------	---------------------	----------------