

Environmental Services Analysis Report - Final

Invoice Number: 3514288	Collected Date: 15-Sep-2025 11:01 AM
Sample Location: Town Shop	Received: 16-Sep-2025 12:53 PM
Collected by: Kelly Kish	Reported: 17-Sep-2025 10:31 AM
Station #: SK05NE0001	Water Source: Distributed
Submitted By: KIPLING TOWN OF BOX 299 KIPLING, SK S0G 2S0	Permit: 2277 KIPLING DIST.SYSTEM
	Invoice: KIPLING TOWN OF BOX 299 KIPLING, SK S0G 2S0

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

Submitter Phone Number: 306-736-8805

Emailed results to: b.ackerman@townofkipling.ca
kellykish1964@gmail.com

Comments:

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include
Invoice Number
with payment
and remit to:

**Saskatchewan Health Authority
c/o Accounts Receivable
2180 23rd Avenue
Regina, Saskatchewan
S4S 0A5**

Total Fees (including GST)	23.00
Tax Summary	1.10
G.S.T. (reg # 89583 0180 RT001)	
Amount Received: (No Payment Received)	0.00

Balance Due upon receipt of invoice.

Balance Owed	\$23.00
---------------------	----------------

Contact Us:

Result Interpretation: Please contact your EPO for advice or phone 1-866-727-5420

Billing Inquiries: Phone: 1-833-989-5353, Email: SHAAR@saskhealthauthority.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine:	.83	Total Chlorine:	.84	Turbidity:	.11
----------------	-----	-----------------	-----	------------	-----