

Environmental Services Analysis Report - Final

Invoice Number: 3511983
Sample Location: 621 Main St
Collected by: Kelly Kish
Station #: SK05NE0001
Submitted By: KIPLING TOWN OF
BOX 299
KIPLING, SK
S0G 2S0

Permit: 2277
KIPLING DIST.SYSTEM

Collected Date: 18-Aug-2025 10:50 AM
Received: 19-Aug-2025 1:49 PM
Reported: 20-Aug-2025 2:30 PM
Water Source: Distributed

Invoice:
KIPLING TOWN OF
BOX 299
KIPLING, SK
S0G 2S0

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

Submitter Phone Number: 306-736-8805

Emailed results to: b.ackerman@townofkipling.ca
kellykish1964@gmail.com

Comments:

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include
Invoice Number
with payment
and remit to:

**Saskatchewan Health Authority
c/o Accounts Receivable
2180 23rd Avenue
Regina, Saskatchewan
S4S 0A5**

Total Fees (including GST) 23.00

Tax Summary 1.10
G.S.T. (reg # 89583 0180 RT001)

Amount Received: (No Payment Received) 0.00

Balance Due upon receipt of invoice.

Balance Owed	\$23.00
---------------------	----------------

Contact Us:

Result Interpretation: Please contact your EPO for advice or phone 1-866-727-5420
Billing Inquiries: Phone: 1-833-989-5353, Email: SHAAR@saskhealthauthority.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine: 0.64 Total Chlorine: 0.66 Turbidity: 0.12