

## Environmental Services Analysis Report - Final

<b>Invoice Number:</b> 3447485	<b>Collected Date:</b> 06-Nov-2023 6:39 AM
<b>Sample Location:</b> ESSO	<b>Received:</b> 06-Nov-2023 11:29 AM
<b>Collected by:</b> Kelly Kish	<b>Reported:</b> 07-Nov-2023 10:49 AM
<b>Station #:</b> SK05NE0001	<b>Water Source:</b> Distributed

**Permit: 2277**  
KIPLING DIST.SYSTEM

<b>Submitted By:</b> KIPLING TOWN OF BOX 299 KIPLING, SK S0G 2S0	<b>Invoice:</b> KIPLING TOWN OF BOX 299 KIPLING, SK S0G 2S0
--	---

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	<b>1</b>	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	<b>2</b>	

<b>Submitter Phone Number:</b> 306-736-2515	<b>Emailed results to:</b> kiptown@sasktel.net kellykish@swwa.ca
---	---

**Comments:**

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include Invoice Number with payment and remit to:	<b>Saskatchewan Health Authority</b> <b>c/o Finance</b> <b>2180 23rd Avenue</b> <b>Regina, Saskatchewan</b> <b>S4S 0A5</b>	Total Fees (including GST)	23.00
		Tax Summary	1.10
		G.S.T. (reg # 89583 0180 RT001)	
		Amount Received: (No Payment Received)	0.00

Balance Due upon receipt of invoice.

<b>Balance Owed</b>	<b>\$23.00</b>
---------------------	----------------

**Contact Us:**

*Result Interpretation:* Please contact your EPO for advice or phone 306-535-4347  
*Billing Inquiries:* Phone: 1-833-989-5353, Email: shaar@saskhealthauthority.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine: 0.47	Total Chlorine: 0.48	Turbidity: 0.13
---------------------	----------------------	-----------------