

## Environmental Services Analysis Report - Final

**Invoice Number:** 3414571  
**Sample Location:** 621 Main St.  
**Collected by:** Kelly Kish  
**Station #:** SK05NE0001

**Permit:** 2277  
KIPLING DIST.SYSTEM

**Collected Date:** 15-Aug-2022 7:28 AM  
**Received:** 15-Aug-2022 3:43 PM  
**Reported:** 16-Aug-2022 2:27 PM  
**Water Source:** Distributed

**Submitted By:**  
KIPLING TOWN OF  
BOX 299  
KIPLING, SK  
S0G 2S0

**Invoice:**  
KIPLING TOWN OF  
BOX 299  
KIPLING, SK  
S0G 2S0

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

**Submitter Phone Number:** 306-736-2515

**Emailed results to:** kiptown@sasktel.net  
kellykish@swwa.ca

### Comments:

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include  
Invoice Number  
with payment  
and remit to:  
**Saskatchewan Health Authority  
c/o Finance  
2180 23rd Avenue  
Regina, Saskatchewan  
S4S 0A5**

**Total Fees (including GST)** 23.00

**Tax Summary** 1.10  
G.S.T. (reg # 89583 0180 RT001)

**Amount Received: (No Payment Received)** 0.00

Balance Due upon receipt of invoice.

<b>Balance Owed</b>	<b>\$23.00</b>
---------------------	----------------

### Contact Us:

**Result Interpretation:** Please contact your EPO for advice or phone 306-535-4347  
**Billing Inquiries:** Phone: (306) 766-5832, Fax: (306) 766-5188, Email: corpfinance@rqhealth.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine: 1.55      Total Chlorine: 1.58      Turbidity: 0.12