

Environmental Services Analysis Report - Final

Invoice Number: 3513688	Collected Date: 08-Sep-2025 10:15 AM	
Sample Location: Water Plant	Received: 09-Sep-2025 12:24 PM	
Collected by: Kelly Kish	Reported: 10-Sep-2025 10:36 AM	
Station #: SK05NE0001	Water Source: Distributed	Permit: 2277 KIPLING DIST.SYSTEM

Submitted By: KIPLING TOWN OF BOX 299 KIPLING, SK S0G 2S0	Invoice: KIPLING TOWN OF BOX 299 KIPLING, SK S0G 2S0
--	---

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
Regular Panel					23.00
Total Coliform	No Detectable	orgs/100 mL	No orgs/100 mL	1	
E. Coli	No Detectable	orgs/100 mL	No orgs/100 mL	2	

Submitter Phone Number: 306-736-8805	Emailed results to: b.ackerman@townofkipling.ca kellykish1964@gmail.com
---	---

Comments:

1. Testing result indicates that your water meets the Bacteriological standard for Canadian drinking water quality.
2. See above for comment

Please include Invoice Number with payment and remit to:	Saskatchewan Health Authority c/o Accounts Receivable 2180 23rd Avenue Regina, Saskatchewan S4S 0A5	Total Fees (including GST) 23.00 Tax Summary 1.10 G.S.T. (reg # 89583 0180 RT001)
---	--	---

Amount Received: (No Payment Received) 0.00

Balance Due upon receipt of invoice.

Balance Owed	\$23.00
---------------------	----------------

Contact Us:

Result Interpretation: Please contact your EPO for advice or phone 1-866-727-5420
Billing Inquiries: Phone: 1-833-989-5353, Email: SHAAR@saskhealthauthority.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the results.

Free Chlorine: .67	Total Chlorine: .69	Turbidity: .10
--------------------	---------------------	----------------